

## ADDENDUM

Document 00910-CSP

### ADDENDUM NO. 3

Date of Addendum: 5/11/2021

PROJECT NAME: TC Jester Park Playground  
PROJECT NO: F-COC003-0001-4

PROPOSAL DATE: May 20, 2021

FROM: City of Houston, General Services Department  
900 Bagby, 2nd Floor, City Hall Annex  
Houston, Texas 77002  
Attn: Sara Krouskop, Project Manager

TO: Prospective Proposers

This Addendum forms a part of the Proposal Documents and will be incorporated into the Contract, as applicable. Insofar as the original Project Manual and Drawings are inconsistent, this Addendum governs.

### CHANGE IN PROPOSAL DATE

The Proposal Date for this Project is changed from **May 13, 2021** to **May 20, 2021**. Time of day and place for submittal of Proposal remains the same.

### CLARIFICATIONS

1. Specification Document No. 00200CSP, Instructions to Proposers, dated January 1, 2020 - No substitutions will be accepted before the project is awarded.
2. Sheet L1.22 - There are no shade covers for this playground.
3. Sheet L1.40 - There is no existing irrigation system to be used to establish proposed seeded areas. Contractor's responsibility is to establish lawn using their own means and methods.
4. Sheet L2.03, Detail 8 - see notes which clarify the process for creating and reaching approval for the exposed aggregate surface. (no sandblast finish)
5. Sheet L2.04, playground perimeter fence color to be black.
6. Sheet IR 1.0 - There is no existing irrigation system in place. Contractor's responsibility is to install irrigation system as shown on drawings and to utilize the existing water meter.

END OF ADDENDUM NO. 3

DocuSigned by:

*Richard A. Vella*

A597721A7EB34B6

Richard Vella  
Assistant Director  
Real Estate, Design & Construction Division  
General Services Department

DATED: 5/11/2021